Labor	-Brazil -zip Phone +55(31)		UFMG			
RE:	165	7/19	Date of Issue	Dec 16 th 2019	Сору:	2- cancels andreplaces copy 1
Applicant/Contact: Address: Sample: Client Identif.: NOTE:	Logitec Assessor AlvarengaGomes Av. das Américas, TYPE C GASOLIN Sample with Green Plu	2480, bl 02, sl 314, E - REGULAR s additive.	Barra da Tijuca, Ri Entry Lab Date: Date of Collection/Samp.:	Romão and Venâne o de Janeiro, RJ. : Nov 21 st , 2019 Nov 21 st , 2019 : Oct 30 ^{th,} 2019	cio	
Assay	Unit	Method	Result	Date of test	Specification, where applicable Inform which was used: RANP No. 40 of 2013	Uncertainty (U) or Limit of Indeterminacy (LI), if applicable Inform which was used: LI
Aspect	-	ASTM D 4176-04 (2014)	Clear and free from impurities	Dec 11 ^{th,} 2019	Clear and free from impurities	-
Color	-	Visual-IT-LEC-00- 11 rev.14	Orange	Dec 11 ^{th,} 2019	Except blue	-
Content of Anhydrous Ethanol Fuel	% v/v	NBR 13992-2015	27	Dec 09 ^{th,} 2019	26 to 28	25 to 29
Specific mass at 20°C	kg/m ³	ASTM D 4052-18a	749,0	Nov 29 ^{th,} 2019	-	-
Vapor Pressure at37.8ºC	kPa	ASTM D 5191-19	53,3	Dec 05 ^{th,} 2019	Max. 69	-
Current Washed Gum, max	mg/100 mL	ASTM D 381-12 (2017)	1,4	Dec 09 ^{th,} 2019	Max. 5	-
Induction Period	min	ASTM D 525-12a	> 360	Dec 09 ^{th,} 2019	Min. 360	-
Copper Corrosivity at50°C, 3h	-	ASTM D 130-19	1b	Dec 09 ^{th,} 2019	Max. 1	-
Sulphur content	mg/kg	ASTM D 5453-19	39	Dec 04 ^{th,} 2019	Max. 50	63
T 10% of distillation	٥C	ASTM D 86-18	55,0	Nov 29 ^{th,} 2019	Max. 65	66,9
T 50% of distillation	°C	ASTM D 86-18	72,1	Nov 29 ^{th,} 2019	Max. 80	81,1
T 90% of distillation	°C	ASTM D 86-18	158,1	Nov 29 ^{th,} 2019	Max. 190	193,1
Final Boiling Point	°C	ASTM D 86-18	217,5	Nov 29 ^{th,} 2019	Max 215	219,7
Distillation residue	mL	ASTM D 86-18	1,1	Nov 29 ^{th,} 2019	Max. 2	2,2
Methanol content	% v/v	NBR 16041-2015	< 0,1	Dec 03 ^{rd,} 2019	Max. 0.5	-
Lead*	g/L	ICP / OES	< 0,00001	Dec 05 ^{th,} 2019	Max. 0.005	-
Phosphorus	g/L	ASTM D3231-18	0,60	Dec 10 ^{h,} 2019	Max. 1.3	
Hydrogen Content*	%	Elementary Analysis	-	-	-	-
Higher CalorificValue	MJ/kg	ASTM D 240-17	39,812	Dec 09 ^{th,} 2019	-	-
Lower Calorific Value	MJ/kg	ASTM D 240-17	-	-	-	-
Acidity Index	mgKOH/g	ASTM D 664-18e2	< 0,01	Dec 03 ^{rd,} 2019		-

Antônio Carlos, 6627-Campus Pampulha-Belo Horizonte/MG-Brazil -zip code:31.270- 901 Phone:+55(31) 3409-6650 / 6651 / 7578			UFMG						
RE	165	7/19	Date of Issue:	Dec 16 ^{th,} 2019	Сору:	2- cancels and replaces copy 1			
Applicant/Contact:	Logitec Assessori Gomes	a em Logística Ltda / Wilson José Romão and Venâncio Alvarenga							
Address:	Av. das Américas, 2	2480, bl 02, sl 314, Barra da Tijuca, Rio de Janeiro, RJ.							
Sample:	TYPE C GASOLINE	- REGULAR	Entry Lab Date:	Nov 21 st , 2019					
Client Identif.:	Sample with Green Plus	additive.	Collection Date/Samp.:	Nov 21 st , 2019					
NOTE:	-		Date of Service:	Oct 30 ^{th,} 2019					

The Common Gasoline fuel was collected at the fuel distribution base, located in Betim-MG, in 1L glass bottles, previously cleaned. At the time of collection the bottles were washed with the fuel itself, this portion was discarded and later a new aliquot was sampled. The bottles were capped and sent to the LEC/UFMG. (Fuel testing laboratory Federal University of Minas Gerais)

Procedural deviations:

NA

NOTE:

*Subcontracted testing.

Preparation:

The fuel type Regular Gasoline was transferred to a previously cleaned amber glass flask with a 4L capacity in order to adequately homogenize the entire volume.

1 L was separated in a high density PET bottle, previously cleaned to be analyzed as fuel without additive (reference for mixtures with additive).

The GREEN PLUS fuel + additive mixture was prepared at the client's requested concentration of 0.038% by volume (23 mL for 60 L) using the following material:

• Class A volumetric flask, BVL 214, nominal capacity 1000 mL, calibrated by a laboratory belonging to RBC (Engecal)(Brazilian Labs Calibration Network - Certified by INMETRO), CER58906/18, calibration validity 08/2028.

• Micropipette, adjustable volume, MCP 768, nominal capacity 0.1 to 1 mL, calibrated by a laboratory belonging to the RBC (Engecal), CER18795/19, expiry date 05/2021.

The results presented in this report refer exclusively to the sample cited.

Sample according to the ANP (National Petroleum Agency) specifications for the evaluated characteristics.

Report:

RANP No. 40 of 2013 and ANP Indeterminacy Limits.

Interpretation:

Decision rule of the report :

NA

NA or - : Not Applicable.

Qarolina Q. Langa

Carolina do Carmo Souza Responsible Chemist for Regular Tests CRQ (Chemistry Regional Council) NUMBER: 02101288

Final document.